

**OFFICE OF THE DIRECTOR FIRE & EMERGENCY SERVICES J&K,
SRINAGAR/JAMMU**

The Principal,
Goodwill School,
Aishmuqam Anantnag.

No. DFES/FP/9/2023-04/CC-7079422-535


Dated. / 0 - 02.2026

Sub. - Fire & Life safety measures/guidelines in favour of "Goodwill School" situated at Aishmuqam
Latroo Anantnag.

Ref: Your application submission date, 11-12-2025.

The inspection of above said school was got carried out by the Deputy Director F&ES Command Anantnag vide his office letter No. DDF&ES-A/FP/2026/176 dated, 28-01-2026 and found that the management has installed 09 units ABC type 02 kg, 01 unit DCP type 10 kg, 01 unit water type 09 liters & 01 unit ABC type 10kg capacity first aid fire extinguishers in their school premises. However, the site is about 04 Km away from Fire & Emergency Station City Chowk Anantnag and is accessible for fire tenders in case of any exigency. Since the school is already functioning, as such the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there:-

1. 01 No. of water type 09 liters capacity fire extinguisher shall be provided in each floor of all the school buildings & 01 No. each CO2 type 4.5 kg capacity fire extinguishers shall be provided near electric panel switch board & in computer lab, in addition to already existing fire extinguishers.
2. Hose Reel as per BIS specifications connected with terrace tank of 10000 Ltrs. capacity shall be provided in each floor of the double storeyed school building & 01 No. hose reel in the center of all the single storeyed structures. The Hose Reel shall be kept at such a place where from every nook and corner of all the structures are covered easily at the time of any emergency. A Fire pump of desired capacity shall be installed near terrace water storage tank with dual electric supply for feeding the Hose Reel.
3. Wooden components of the structures especially in attic portion shall be given fire retardant treatment of at least two hours rating.
4. All exits/entrances shall be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency. The corridor of the buildings shall not be used for any kind of storage.
5. First Aid Fire fighting system installed in the school building shall be checked periodically. Staff and students shall be fully trained in handling/operating of fire fighting system installed in the school building.
6. No Hazardous material shall be kept inside of the school premises (especially LPG cylinder, Petrol, Diesel and Central Heating System etc.) Any deviation found in this regard, these fire safety measures/guidelines issued will be treated automatically withdrawn/cancelled.
7. The Management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
8. Class/Halls have a capacity of more than 45 students shall have two exits. Grill fitted in the windows shall be removed. Fire/Evacuation drill shall be conducted regularly.
9. At present school is functioning in 08 structures, Block "A" is "L" shaped double storeyed CGI sheet roofed having dimension 100'X30' provided with single staircase of 1.20 meters wide. Block "B" are 03 CGI sheet roofed hut type with equal dimension 45'x22' with wooden ceiling. Each hut comprises upon 02 class rooms. Block "C" are 03 CGI sheet roofed hut type with equal dimension 45'X22' with wooden ceiling. Each structure comprised upon 02 class rooms. Block "D" is single storeyed CGI sheet roofed hut type is under construction having dimension 45'X20' comprised upon 01 examination hall. As such no addition/alteration shall be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, these fire safety measures/guidelines will be treated automatically withdrawn/cancelled.
10. An additional staircase of 1.5 meters wide well away from the existing exit shall be provided in the double storeyed school building for the safe and hassle free evacuation of inmates during any emergency.
11. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (proposed) found defunct and deviation, these fire safety measures/guidelines issued shall be treated automatically withdrawn/cancelled.
12. The students of preschool, kindergarten, up to class 1st shall be accommodated on ground floor and class 2nd students shall be accommodated not above 1st floor of the building.
13. These fire & life safety measures/guidelines shall be subject to outcome of any disputed investigation enquiry/trial if any pending before any court of Law/investigation agency. These fire & life safety measures/guidelines shall not confirm any title upon the person/company in whose favour it is issued. Furthermore the status with regards to land shall be the responsibility of the concerned registering authority.
14. The instant fire safety measures is strictly for adoption of fire safety recommendations/guidelines of the occupancy only and not for authentication of any other claim.
15. While leaving final registration /permission to above said establishment, the authority concerned may ensure the fire safety recommendation/guidelines given to the school by this department are fully complied with.
16. These fire & life safety measures/guidelines are issued in respect of the installation with a validity of six months for adoption & same needs to be renew after inspection/checking of entire fire fighting system installed in the school the existing as well as proposed by the technical officer of this department. However, before granting permission/recognition/extension or renewal thereof, the competent authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 & SRO-292 of 2018, issued by Education Department with regard to Physical facilities.


Director,
Fire & Emergency Services, J&K,
Jammu/Srinagar

10/02/2026