



Government of Jammu & Kashmir  
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER JAL SHAKTI (PHE)  
SUBDIVISION PAHALGAM (HQ AISHMUQAM)

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No: *PHP/26*

Dated: *15-04-2026*

It is certified that an inspection team headed by **Er. Nazir Ahmad Wani (Assistant Engineer)** from PHE Sub Division Pahalgam (HQ Aishmuqam) inspected the **Army Goodwill School Aishmuqam Anantnag Kashmir** on **09/04/2026** and on the basis of Water Test Report (Attached) bearing No. **WTLPA/228/217** Dated **09 & 10-04-2026** issued by **Sub Divisional Water Quality Testing Laboratory Pahalgam**, certified that the school has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed.

This certificate is valid till 6 Months from the date of issuance and subjected no adverse change in water quality.

*Asst. En. Engineer*  
*P.H.E. Sub Division*  
*Pahalgam (HQ) Aishmuqam*  
Er ~~Paswat~~ Ahmad Malik,  
Assistant Executive Engineer,  
Jal Shakti PHE Sub Division,  
Pahalgam(HQ Aishmuqam).

**KASHMIR PUBLIC HEALTH ENGINEERING DEPARTMENT**  
**WATER QUALITY MONITORING**  
**SUB-DIVISIONAL WATER TESTING LABORATORY PAAHALGAM**  
**ANANTNAG**  
**PHYSICO-CHEMICAL WATER ANALYSIS ROUTINE PARAMETER REPORT**

**SAMPLE DESCRIPTION:**

Source: Bore Well  
 Scheme: Army Govt Will School  
 Status: RAW  
 Block: Pahalgam  
 Collected by/Forwarded by: School Employee

Laboratory Ref. no: WTLPA/228/217  
 Place of Collection: Aishmulqam  
 Date of Collection: 09-04-2026  
 Date of Examination: 09/10-04-2026

**REPORT.**

S.No	Parameters	Units	Result	Permissible limits	Max. Tolerance limits
1.	Turbidity	N.T.U	2.36	1	5
2.	pH <u>25</u> °C	.....	7.20	6.5 to 8.5	8.5
3.	Free Residual Chlorine	Mg/L	0.0	0.2	>1.0
4.	Conductivity	µs/cm	212	.....	.....
5.	Total Dissolved Solids (T.D.S)	Mg/L	196	500	2000
6.	Color	Hazen	5.0	5	15
7.	Taste and Odour	.....	TL/OL	Unobjectionable	
8.	Total Hardness (C <sub>2</sub> CO <sub>3</sub> )	Mg/L	75	200	600
9.	Total Alkalinity	Mg/L	90	200	600
10.	Total Iron (Fe)	Mg/L	0.0	<0.3	0.3
11.	Nitrates (NO <sub>2</sub> )	Mg/L	0.0	45	45
12.	Phosphate	Mg/L	0.0	1.0	1.5
13.	Fluoride (F)	Mg/L	0.0	1.0	1.5
14.	Chloride (CL)	Mg/L	40.0	250	1000
15.	Calcium (ca)	Mg/L	-	75	200
16.	Arsenic (As)	Mg/L	-	0.01	0.05
17.	Bacteria	-	ABSENT	Absent	Absent

*[Signature]*  
 09/10/26

*[Signature]*  
 CHEMIST  
 09/10/26

**Impression:-** All the above tested parameters are found within their normal ranges. Hence, water is safe for drinking purposes.

*[Signature]*  
 09/10/26  
 BE making Lab sec